

Amendment No. 1**Date: 20/08/2018****Subject: Amendment to the Tender Enquiry Document.****Ref: Tender no. HMC/Diesel Generator Set/2018/006 dated 12.08.2018**

The following changes have been incorporated in the referred tender:

Sr. No.	Clause No.	Page No.	Existing	To be Read As
1	Tender Time Line (Point no. 3)	03	Closing date & time for Submission of Bids - 22.08.2018 at 2.00 PM	Closing date & time for Submission of Bids - 23.08.2018 at 6.30 PM
2	Tender Time Line (Point no. 3)	03	Time & date for Opening of Technical Bid - 22.08.2018 at 3.00PM	Time & date for Opening of Technical Bid - 24.08.2018 at 11.30 AM
3	EMD (Point no. 02)	04	Tenderer would be required to submit Interest free Earnest Money Deposit (EMD) in the form of Demand Draft in favor of 'HLL Mother & Child Care Hospitals Ltd.' payable at Noida in the envelope containing Technical Bid (as per GIT clause no.12.1).	Tenderer would be required to submit Interest free Earnest Money Deposit (EMD) in the form of Demand Draft / FDR in favor of 'HLL Mother & Child Care Hospitals Ltd.' payable at Noida in the envelope containing Technical Bid (as per GIT clause no. 12.1).
4	Price Bid	07	Prices to be quoted in the prescribed Price Bid format in excel provided along with the tender enquiry. The prices should be quoted for the accounting unit indicated in the tender document.	Prices to be quoted in the prescribed Price Bid format in the tender enquiry. The prices should be quoted for the accounting unit indicated in the tender document.
5	GIT – EMD (Point no. 12.1)	09	The tenderer shall furnish along with its tender, earnest money of Rs.5,25,000/- (Rupees Five Lakhs & Twenty Thousand Only) in form of Account Payee demand draft to be drawn on any scheduled commercial bank in India in favour of the "HLL Mother & Child Care Hospitals Limited" payable at Noida.	The tenderer shall furnish along with its tender, earnest money of Rs.5,25,000/- (Rupees Five Lakhs & Twenty Thousand Only) in form of Account Payee Demand Draft / FDR to be drawn on any scheduled commercial bank in India in favour of the "HLL Mother & Child Care Hospitals Limited" payable at Noida.
6	General Conditions of the	22	The consignee will enter into CMC with the supplier at the rates as stipulated in the contract after completion of	The consignee will enter into CMC with the supplier at the rates as stipulated in the contract after

HLL Mother & Child Care Hospitals Limited

	Contract (Point no. 15.2)		Defect liability Period i.e. 12 months after successful handing over of the DG Sets. The payment of CMC will be made on six monthly basis after satisfactory completion of said period, duly certified by the consignee on receipt of bank guarantee for an amount equivalent to 2.5 % of the cost of DG Set System as per contract in the prescribed format given in Section XV valid till 2 months after expiry of entire CMC period.	completion of Warranty Period i.e. 05 years after successful handing over of the DG Sets. The payment of CMC will be made on six monthly basis after satisfactory completion of said period, duly certified by the consignee on receipt of bank guarantee for an amount equivalent to 2.5 % of the cost of DG Set System as per contract in the prescribed format given in Section XV valid till 2 months after expiry of entire CMC period.
7	General Conditions of the Contract (Point no. 16.1)	23	If the supplier fails to delivered, installation & commissioning of the entire system on or before the stipulated date, then a penalty at the rate of 2% per week of the total order value shall be levied subject to maximum of 10% of the total order value.	If the supplier fails to delivered, installation & commissioning of the entire system on or before the stipulated date, then a penalty at the rate of 1% per week of the total order value shall be levied subject to maximum of 5% of the total order value.
8	Technical Specifications (Point no. 04)	28	24 Volt chargeable lead acid batteries set complete with battery leads.	12 Volt chargeable lead acid batteries set complete with battery leads / starter.
9	Technical Specifications (Point no. 05)	28	The DG shall be mounted on a fabricated rigid common base frame with GERB/Dunlop make anti vibration mounting for vibration isolation as specified.	The DG shall be mounted on a fabricated rigid common base frame with GERB/Dunlop make anti vibration mounting for vibration isolation or within the canopy with AVM pads for vibration isolation as specified.

Clarification to Tender Terms:

Sl. No.	QUERY	REPLY TO BIDDER'S QUERY
TECHNICAL		
1	Ideally there should be 4 earthing foreach Dgset but if the scope of installation is not clear then people manage with less of them.	04 earthings shall be provided for each D.G. Set as per CPCB norms.

HLL Mother & Child Care Hospitals Limited

2	Is platform in the scope of installation or not.	Platform shall be provide by HMC for placement of DG set
3	In the General Technical specifications point no. 1 page no. (29) what is vacuumatic parts.	Warranty / CMC of Vaccumatic parts to be considered if applicable to the DG Set being quoted.
4	Comprehensive warranty cover consumable also like filter, lube oil, coolant etc	Comprehensive warranty shall include all consumables like filter, lube oil, coolant, etc.
5	AVM Pads will be inside of canopy not between foundation & DG.	AVM Pads shall be installed inside canopy.
6	As per page no 28 Section VII technical specifications Notes point no 2. AMF panel with PLC, since we have feature in our engine mounted controller of AMF facility hence please remove PLC.	PLC may be omitted.
7	The Remote start not required with AMF application.	Remote start is not required with AMF application
8	The Department has to do foundation , Earthing , Control wiring , and not clear in tender . The Power cable DG set to LT panel size & Length is to be clarify .	Foundation for placement of DG Set will be provided. Power cable to be quoted on per meter basis.
COMMERCIAL		
1	In Page no 4 Point no 8 in Specific Instruction which Licenses is require pl clarify . Government is not issuing any permission for Operation of DG Set .	Any certification / license required against statutory compliance for working of DG set shall be provided by the supplier.
2	In tender the page no 22, point 15, Payment terms please release our payment within 30 days from the commissioning if any delay occurs from your end, our payment will release with in 60days from the date of supply including 10% amount against submission of Performance security.	Tender condition shall prevail.
3	Warranty will be as per manufacture instead of 5 Years as we cannot extend being suppliers.	Warranty shall be of 05 years.
4	IN DG set business the sales & service two different channel and after sales service is given by Manufacturer or their nominated service dealer who take AMC & CAMC After warranty hence we needed separate PO for Supply of DG set and separate PO for CAMC also please consider 5 years warrantee with 5000Hrs whichever is earlier.	Bidder to quote for both supply and CAMC of DG Set. Initial PO will be issued for supply of DG Set. And independent PO shall be issued towards end of 05 year warranty period for the CMC of 05 years as per the quoted rates.

HLL Mother & Child Care Hospitals Limited

5	After delivery the safe storage arrangement will be purchaser responsibility as it is impossible to keep watch & ward at each site.	D.G. Set shall be commissioned upon receipt of D.G. Set at HMC premises. Any extra storage facility required shall be done by supplier.
6	In tender the page no 22, point 15, Payment terms clause 15.2, Two separate PBG should be here one for DG set supply and another for CAMC, PBG for supply part should be released as per our Guarantee warrantee clause.	PBG shall be furnished by bidder against independent PO's for supply and CAMC of DG Set.
7	The buyback clause may be deleted as no one can imagine the condition after 10 Yrs and Buy back agencies are different.	Tender condition shall prevail.
8	Will 5 years warranty start from the date of invoice?	05 yrs. Warranty shall be from the date of commissioning.
9	In the Section-VII technical Specifications page no. (28) Hospital plus grade hospital grade silencer is not required, instead you should ask for generator sound compliance as per CPCB norms.	Hospital grade silencer's are required for the DG sets being supplied.
10	In the General Technical Specifications page no. (29) point no. 4 (c) Performance Bank Guarantee for supply parts and CMC should be separate. After 5 years of supply parts Performance Bank Guarantee of supply should be returned against a new Performance Bank Guarantee of CMC part.	Separate PBG shall be furnished by the supplier against independent PO's for supply & CMC of DG Set.

All other contents of the tender enquiry including terms & conditions remain unaltered.

Note:

- 1. Prospective Bidders are advised to check the website regularly prior to the closing date and time of submission of tenders.**